

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7165-0554:106

Page 1 of 1

**CATEGORY:** Control Unit (Non High-Rise)

**LISTEE:** Johnson Controls, 507 E. Michigan St., Milwaukee WI 53202-5211\*  
Contact: \*James D. Kinney (414) 524-4358 Fax (414) 276-5979

**DESIGN:** System FC2000 fire alarm control unit. Power-limited; non-coded or marchtime; local, auxiliary remote station and proprietary protected premises service; remote releasing device and sprinkler supervisory service. Refer to listee's data sheet for additional product description and operational considerations.

**OPTIONS:** Refer to listee's data sheet for other required/optional accessories. When required, accessories shall be listed by CSFM. (Refer to CSFM Listing No. 7170-0554:105)

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**APPROVAL:** Listed as a fire alarm control unit when used in conjunction with separately listed compatible initiating and indicating signal devices. All wiring connections from the FC2000 to the listed compatible transmitter shall be in conduit.

This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

When used as a proprietary protected premise unit, the system shall be interconnected to Potter Model EFT-C electrically actuated transmitter (CSFM Listing No. 7330-0328:104).

When used as a central station protected premise unit, the system shall be connected to Firelite Model NOTIFIRE 911 series digital communicator which is connected to ADEMCO Model 685 control unit (CSFM Listing No. 7165-0078:133), or a separately listed compatible control unit.

**XLf:** 7165-0028:144

\*Rev. 06-10-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 10, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager